

WILLIAM H. WINCOTT, P.E.

86 Maynard Drive
Egbertsville, New York 14226

February 1, 2013

Perma Tech Inc
Attn: Richard Lund Jr.
363 Hamburg St
Buffalo, N Y 14204

Re: Canopy Test

Dear Mr. Lund:

This letter is to certify that a Perma Tech Inc. 36" x 10'-6" steel canopy, manufactured in accordance with Buflovak drawing #67125-01, successfully passed a simulated snow load test of 80 psf. No permanent deformation or structural failure was observed or evident.

The canopy was attached to an eight inch concrete block wall with 10 - 3/8" thru wall structural grade all thread anchors. Five on the top flange and five on the support struts with standard washers and nuts.

Yours truly,



William H. Wincott, PE

